

LIQUID PROPULSION SYSTEMS CENTRE
MAHENDRAGIRI

Safety and Fire Services

10.09.2007

Ref : Lr.No:SE/P&E/ETPS/EE/MM/A1/Spec No:1842/D640 Dt.21.08.07
from SE, TNEB, Ennore Thermal Power Station, Ennore, Chennai.

The above referred letter was marked to us for our comments. We give the following and the same may be conveyed to the TNEB.


P.O. No. & Value: LPM/16/5526/03/27212 dt.19.03.2004 & Rs.11,40,000/-

Item : Design, Fabrication and Supply of tank for storing TEA (Triethanolamine) Solution.

Material: SA 240 Gr 304 L (Shell)

Capacity: 60 m³

The above mentioned SS tank was designed, Fabricated and Supplied to us by M/s Gulf Engineers and Constructors Pvt Ltd, Chennai under third party inspection by M/s BVIS. Design and dimensions of the tank are as per approved documents and drawings by TP. Materials used are also as per our requirements. The party supplied the item within the delivery period. Water fill test was done and the tank was qualified. The performance of the party w.r.t quality and schedule was good.



(J.Singarayar)

Engr-SD, S&FS,
LPSC, ISRO, Mahendragiri

To

The Purchase & Stores Officer,
LPSC, Mahendragiri.

Through : General Manager, S&FS LPSC, ISRO, Mahendragiri.


I. JONES RABINDRAN
General Manager, S&FS, LMF